**GENERAL NOTES:** 

GREY SHADED LINE WEIGHT DENOTES EXISTING.

NOTES:

THESE DRAWINGS SHALL NOT BE SCALED.

THE CONTRACTOR SHALL VISIT THE SITE AND SATISFY ONESELF ALL DIMENSIONS, DATUM, AND DETAILED INFORMATION SHOWN ARE CORRECT.

THE CONTRACTOR IS TO REVIEW AND COORDINATE ALL ARCHITECTURAL, MECHANICAL, ELECTRICAL AND STRUCTURAL DRAWINGS FOR ADDITIONAL OPENINGS THROUGH FLOORS WALLS, AND CEILINGS FOR DUCT, PIPE & ELECTRICAL RISERS AND ALL OPENINGS NOT SHOWN ON DRAWINGS.

ALL OPENINGS THROUGH THE FIRE SEPARATIONS AS A RESULT OF THE WORK OF THIS CONTRACT ARE TO BE FIRE STOPPED AND SEALED WITH ULC APPROVED FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION, AND PROVIDE AND SMOKE-TIGHT BARRIER. EXISTING OPENINGS THROUGH FIRE SEPARATIONS THAT ARE NOT CURRENTLY FIRE STOPPED TO BE DEALT WITH UNDER SEPARATE CONTRACT.

ALL PRODUCTS AND MATERIALS TO BE USED AND INSTALLED SHALL CONFORM WITH MANUFACTURER'S SPECIFICATIONS & APPLICABLE CODES.

THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH AND MAKE GOOD ALL EXISTING CONSTRUCTION AFFECTED BY THE REMOVAL OF ALL ITEMS FORMING THE PART OF THE RENOVATION WORK.

WHERE NEW FLOORING AND BASE IS TO BE INSTALLED IN EXISTING AREAS (REFER TO FLOOR PLAN AND ROOM SCHEDULE) THE EXISTING FLOORING SURFACE AND BASE MUST BE REMOVED, UNLESS OTHERWISE NOTED. ALL FLOOR SURFACES SHALL BE PREPARED IN ACCORDANCE TO MANUFACTURER'S RECOMMENDATIONS FOR INSTALLATION OF NEW

WHERE PAINTING OF EXISTING WALLS IS INDICATED ON THE ROOM SCHEDULE, THESE WALLS MUST BE CLEANED OF ANY EXISTING WALL COVERING, PATCHED & PREPARED TO ACCEPT NEW MATERIAL, UNLESS OTHERWISE NOTED.

600-MCC-1

G	GLYCOL PUMP LOCKER ROOM	B-1 BOILER	VACUUM PUMP	POOL EXHAUST FAN 9	PRIMARY PUMP #1	SUPPLY FAN WEST WINDOW	DOMESTIC HOT WATER PRIMARY PUMP #1	
	GLYCOL PUMP WEST WINDOW	B-2 BOILER						INCOMING
Gl		B-3 BOILER	SUMP PUMP No.1	POOL EXHAUST FAN 10	PRIMARY PUMP #2	SUPPLY FAN NORTH SPECTATOR	DOMESTIC HOT WATER PRIMARY PUMP #2	
G	SLYCOL PUMP EAST WINDOW	B-4 BOILER						
	BOILER#1	B-5 BOILER	POOL HEAT PUMP	WEST EXHAUST FAN NW F-15	SPARE	SUPPLY FAN SOUTH SPECTATOR	NORTH TRANSFER FAN	SPARE
		B-6 BOILER			SIZE 1			
	BOILER #2	antor.	SPARE	GLYCOL PUMP #1 NE	SPARE	SUPPLY FAN LOCKER ROOM	SOUTH TRANSFER FAN	SPACE
	BOILER #3	SPACE			SIZE 1			SPACE
ВОС	OSTER COIL CONVECTOR PUMP	OD LOF	POOL EXHAUST FAN 7	GLYCOL PUMP #1 SW	SPARE	SUPPLY FAN BOILER ROOM	NORTH EXHAUST FAN	SPACE
	SPACE	SPACE			SIZE 1			SPACE
			POOL EXHAUST FAN 8	SPARE	SUPPLY FAN EAST WINDOW		SOUTH EXHAUST FAN	00105
	SPACE	SPACE ——						SPACE
	F1	F2	F3	F4	F5	F6	F7	F8

600-MCC-1 ELEVATION E05 SCALE: N.T.S.

0 ISSUED FOR TENDER REVISION/DESCRIPTION



DATE 2016.05.03 USER APPROVAL



THE CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

**PROJECT** 

PAN AM POOL REPLACEMENT OF BOILERS

25 POSEIDON BAY SHEET TITLE

ELECTRICAL **DETAILS** 

16-0107-008

KGS GROUP **EAPEGIN** Certificate of Authorization KGS Group No. 245