

MOTOR SCHEDULE:

NO	DESCRIPTION	LOCATION	KW/HP	VOLTS/Ø	PACK UNIT	STARTER					CONDUCTOR	COND SIZE	BREAKER	CIRCUIT	F/A SHUT DOWN	CONTRL BY DIV.	NOTES
						TYPE	FUNC	PL	PB	HOA							
CU-1A	CONDENSING UNIT	OUTDOOR	14.4FLA	208/1Ø		MAG	FVNR	*		*	2#10	1/2"	30A/2P	MD-1			
CU-1B	CONDENSING UNIT	OUTDOOR	14.4FLA	208/1Ø		MAG	FVNR	*		*	2#10	1/2"	30A/2P	MD-1			
CU-2A	CONDENSING UNIT	OUTDOOR	18.6FLA	208/1Ø		MAG	FVNR	*		*	2#8	3/4"	50A/2P	MD-1			
CU-2B	CONDENSING UNIT	OUTDOOR	18.6FLA	208/1Ø		MAG	FVNR	*		*	2#8	3/4"	50A/2P	MD-1			
F-1	FURNACE UNIT	MECHANICAL ROOM	.55 (3/4 HP)	240/1Ø		MAN				*	2#15	1/2"	15A,2P	EXISTING DISTRIBUTION			3
F-2	FURNACE UNIT	MECHANICAL ROOM	.55 (3/4 HP)	240/1Ø		MAN				*	2#12	1/2"	15A,2P	EXISTING DISTRIBUTION			3
AHU-1	AIR HANDLING UNIT	OUTDOOR	156 FLA	240/1Ø	*						2#3/0	2"	200A/2P	MD-1			
EF-1	FAN	ATIC SPACE	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-35			1
EF-2	FAN	ATIC SPACE	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-36 PANEL G			1
EF-3	CRAWLSPACE EXHAUST	CRAWLSPACE	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-45			1
CF-1	PROP FAN	GYM	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-34			1
P-1	WADING POOL PUMP	PUMP HOUSE	3/4HP	208/1Ø		MAN				*	2#12	1/2"	15A,2P	B-46,47			1
P-2	WIPING TILE	CRAWLSPACE	1/3HP	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-48			1
P-3	RECIRC.	MECHANICAL ROOM	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-49			1
P-4	CONDENSATE PUMP	SEE MECH	FRAC	120/1Ø		MAN				*	2#12	1/2"	15A,1P	B-50			1

NOTES:

1. WIRE & CONNECT AS PER MECHANICAL.
2. WIRE & CONNECT REMOTE START AS SUPPLIED BY DIV. 15, INSTALLED BY DIV. 16.



PROJECT: VALOUR COMMUNITY CENTER GYM ADDITION

DWG. NO.:

TITLE: REVISED MOTOR SCHEDULE

RE-3

DATE: JAN 28/08

DRAWN BY: DG

SCALE: NTS

REF. DWG.NO.: