



488-2008 ADDENDUM #1

**NEW PUCK CHLORINATION AND CARBON DIOXIDE SYSTEMS-
VARIOUS OUTDOOR POOLS**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 12,2008
BY: Bill Hickey
TELEPHONE NO. (204)794-4416

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise D2.2(a) major components:

- (i) One(1) model 1030E
- (ii) Eight(8) model 3070AT
- (iii) Delete model 3140AT
- (iv) Nine(9) CO2 Flow Controllers
- (v) Nine(9) BECSys3 Water Chemistry Monitoring and Control Systems.

Revise D2.2(b) equipment list.

Happyland Outdoor pool 470 Marion to ACCU-TAB Model # 3070 AT
Transcona Outdoor Pool 1101 Wabasha to ACCU-TAB Model # 3070 AT
Kildonan Park Outdoor Pool 2021 Main does not require a system .

Add: E6.2 Supply and install one (1) minimum 8"x10" plastic or metal sign at each location as follows: "Caution: Compressed Gas, Carbon Dioxide". Provide sample for Contract Administrator approval.

Add: E6.3 All water piping shall be identified at 10'-0" intervals with a blue band, the word "CHLORINE", and directional arrows.