



746-2008 ADDENDUM 1

510 MAIN STREET DATA CENTRE UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 1, 2008
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, December 10, 2008.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D15.4 to read: The City intends to award this Contract by January 16, 2009.

PART E – SPECIFICATIONS

Add: E2.16: A live floor load of 75 psf is the default capacity for the 7th floor. Any proposals which will increase the floor load should include calculations of the live load capacity based on the structural components in that area.