

606-2014 ADDENDUM 1

REPAIR OF THE NEWPCC SLUDGE CAKE STORAGE BINS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 29, 2014 BY: Colin Siepman, P.Eng. TELEPHONE NO. (204) 896-1209

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E - SPECIFICATIONS

Add: E5.4 NEWPCC will allow the Contractor use of the final effluent discharge piping system,

complete with discharge hoses, couplings and spray nozzles to complete the sludge bin wash-downs outlined in E12. The Contractor shall be aware that this water source is not potable but is acceptable to the Contract Administrator for wash-down purposes. Approximate pressure from this system is 5 bar (75 psi). Connection to this system is available on the upper mezzanine level (top of bin elevation) and at ground level.

Add: E5.4 (a) In the event that the final effluent discharge piping system pressure is found insufficient to

remove all accumulated product on the walls and roof, the Contractor shall use a high pressure system. Connection to the NEWPCC final effluent discharge piping shall be

borne by the Contractor.

Revise: E11.7 (c) (ii) to read: 2 Coats Bar-Rust 235 (6-8 mils DFT per coat) or 2 coats Macropoxy 646 (5-10 mils DFT

per coat). Colour to be safety yellow to match existing.

Add: E11.11 (b) (i): Further to E11.11 (b), accumulation of blast aggregate at the bottom of the sludge cake

storage bins shall be removed by dry methods only, such as sweeping and vacuuming, prior to re-commissioning. The Contractor shall provide coverings to the flight augers to minimize accumulation of blast aggregate within the flight auger flutes and trough.

DRAWINGS

Replace: 606-2014_Drawing_1-0101W-S0002-001-R0 with 606-2014_Addendum_1-Drawing_1-0101W-S0002-001-R1