



ADDENDUM NO. 1 BID OPPORTUNITY NO. 417-2004

2004 OUTFALL GATE CHAMBER CONSTRUCTION AND UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 15, 2004
BY: Coleen Groening /c
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20040901

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, September 22, 2004.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2 (b) to read:

D2.2(b) To read; Construction of a cast-in-place concrete gate chamber addition to the existing concrete gate chamber on the Dunham Road Land Drainage Sewer outfall pipe including supply and installation of cast iron flap gate.

PART E – SPECIFICATIONS

Revise: E10.3 (c) to read:

E10.3 (c) Grout

- (i) Grout shall be Sika Grout 212 or CPD Non-Shrink Grout