


REPAIR EXIST. CONCRETE INLET PIPE (SEE DWG LD-5075)  
 EXIST. CONNECTION PIPE TRANSITIONS FROM 1219mm SQUARE AT INLET PIPE TO 1067mm DIA. ROUND AT STATION  
 REPLACE EXIST. CAST IRON GATE WITH NEW 1067x1067 STAINLESS STEEL SLIDE GATE

SEE DWG. LD-5079 FOR GENERAL NOTES.



**METRIC**  
 WHOLE NUMBERS INDICATE MILLIMETRES  
 DECIMALIZED NUMBERS INDICATE METRES



B.M. XX-XXX ELEV. XXX.XXX				
DESIGNED BY CMS	CHECKED BY CMS	ENGINEER'S SEAL	ORIGINAL DRAWING SIGNED BY: C.M. SIEPMAN	DATE 08/09/23 YY/MM/DD
DRAWN BY FV	APPROVED BY	CONSULTANT DRAWING NO. 08-0107-03-S2	SHEET OF 02 OF 11	
SCALE: AS NOTED	RELEASED FOR CONSTRUCTION:	CAD FILE DRAWING NUMBER 08-0107-03-01		
ISSUED FOR CONSTRUCTION 08/09/23	DATE 08/02/28	CITY DRAWING NUMBER LD-5077		

**KGS GROUP**  
 CONSULTING ENGINEERS & PROJECT MANAGERS  
 WINNIPEG (204) 896-1209  
 THUNDER BAY (807) 345-2233

ENGINEER'S SEAL  
 ORIGINAL DRAWING SIGNED BY:  
 C.M. SIEPMAN  
 DATE: 08/09/23  
 YY/MM/DD

**THE CITY OF WINNIPEG**  
 WATER & WASTE DEPARTMENT  
 WINNIPEG

**RAVELSTON LAND DRAINAGE PUMPING STATION UPGRADE**

**STRUCTURAL STATION SECTIONS**

COWLEND