



942-2020 ADDENDUM 4

PARTIAL ROOF REPLACEMENT AT FORT ROUGE GARAGE – 421 OSBORNE STREEY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 23, 2021
BY: Adolfo Laufer
TELEPHONE NO. 204 986-2380

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

- Q1: Would it be acceptable to install one layer of Polyiso to achieve specified R-value in lieu of two layers? As long as the system meets R25?
- A1: This would only be acceptable if it is done in conjunction with the approved HD ISO coverboard