

439-2021 ADDENDUM No. 2

WINNIPEG TRANSIT GARAGE BUILDING HOIST REPLACEMENT PROGRAM PHASE 2 – HOISTS 8 TO 12

ISSUED:

BY:

**URGENT** 

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL TELEPHONE NO. 204 928-8844 THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM

A PART OF THE CONTRACT DOCUMENTS

Stantec Consulting Inc.

Ian Rossnagel

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

## PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, August 25, 2021.

## PART E - SPECIFICATIONS

 Revise:
 E1.4
 New Section 01 21 00 – Allowances added as follows.

 New Section 01 35 29 – Health and Safety Requirements added as follows

 New Section 02 81 01 – Hazardous Materials Use and Abatement added as follows.

 New Section 02 82 00.01 – Asbestos Abatement Requirements added as follows.

 New Section 02 82 00.02 – Type 2 Work Procedures added as follows.

E1.4 The following are applicable to the Work:

Specification No.		Specification Title
NMS BOOK SPECIFICATIONS DIVISION 01 –		GENERAL REQUIREMENTS
01 14 00 01 21 00 01 26 13 01 29 73 01 31 19 01 32 16.16 01 32 33 01 33 00 01 35 18 01 35 29 01 35 43 01 45 00 01 51 00 01 52 00 01 56 00 01 61 00 01 73 00 01 74 11 01 74 21 01 78 00 01 91 13 01 94 41		Work Restrictions Allowances Requests for Information (RFI) Schedule of Values Project Meetings Construction Progress Schedule - Critical Path Method (CPM) Photographic Documentation Submittal Procedures Alteration Project Procedures Health and Safety Requirements Environmental Procedures Quality Control Temporary Utilities Construction Facilities Temporary Barriers and Enclosures Common Product Requirements Execution Cleaning Construction/Demolition and Waste Management and Disposal Closeout Submittals General Commissioning (CX) Requirements Demonstration and Training
DIVISION 02 02 50 00 02 41 19.14 02 81 01 02 82 00.01 02 82 00.02	-	EXISTING CONDITIONS Site Remediation Selective Demolition for Minor Works Hazardous Materials Use and Abatement Asbestos Abatement Requirements Type 2 Work Procedures
DIVISION 03 03 10 00 03 20 00 03 30 00 03 35 13 03 35 46	-	CONCRETE Concrete Forming and Accessories Concrete Reinforcing Cast-In-Place Concrete High-Tolerance Concrete Floor Finishing Concrete Topical Treatments
DIVISION 09 09 91 00	-	FINISHES Painting
DIVISION 14 14 45 29	-	CONVEYING EQUIPMENT Two Post Inground Bus Hoist
DIVISION 31 31 23 33 31 63 23	-	EARTHWORK Excavating, Trenching and Backfilling Bored Concrete Piles
DIVISION 32 32 11 16		EXTERIOR IMPROVEMENTS Granular Subbase and Base Course

## **NMS SPECIFICATIONS**

Section 01 21 00 – Allowances.		
Add:	New Section 01 21 00 – Allowances.	
Section 01 35 29 – Health and Safety Requirements.		
Add:	New Section 01 35 29 – Health and Safety Requirements.	
Section 02 81 01 – Hazardous Materials Use and Abatement.		
Add:	New Section 02 81 01 – Hazardous Materials Use and Abatement.	
Section 02 82 00.01 – Asbestos Abatement Requirements.		
Add:	New Section 02 82 00.01 – Asbestos Abatement Requirements.	
Section 02 82 00.02 – Asbestos Abatement Requirements – Type 2 Work Procedures		
Add:	New Section 02 82 00.02 – Type 2 Work Procedures.	
Section 02 82 00.02 – Asbestos Abatement Requirements – Type 2 Work Procedures		

## **QUESTIONS AND ANSWERS**

Q1: Can you confirm what voltage you have from the first phase? I checked my records and called our electrician and he agrees that they are 575v or what we call 600v motors.

A1

The second phase hoists are being fed from the same panel as the first phase hoists, which is a 600V panel.

Q2: Please confirm if Division-26 is responsible for the supply and installation of the Unistrut support and backplate as it was done by Transit in Phase-1?

A2:

The General Contractor is to coordinate which division will supply and install the hoist control support structure, but it will not be provided by Winnipeg Transit.

Q3 Please confirm if the Hoist Supplier will be supplying the Hoist Control Panels which looks to include the local disconnect switch, magnetic starter, control transformer, etc.?

A3:

The hoist control panels will be provided by the Hoist Supplier and coordinated by the General Contractor.

Q4 Rotary the Lift Manufacturer has stated their motors normally come rated at 475 volts. The specifications state that the motors are to be 600 volts. Rotary cannot guarantee supply of 600 volt motors at this time and there is an upcharge to change from the standard 475 volts to 600 volts?

A4:

See Q1 / A1.

Tender No. 439-2021 Addendum No. 2

Q5 In Addendum #1 under Section 02 50 00 Site Remediation under 1.6 Containment of Material on Site it asks to temporarily store all groundwater on site. During Phase 1, Parkwest Projects had a pump running 24/7 during the entire project. The cost to store that volume of water on site would be very expensive. Is this an item that needs to be included?

A5:

.

Phase 1 appeared to run the groundwater into the existing oil / water separator interceptor pits. Assume that this can be done for Phase 2.