



## 52-2024 ADDENDUM 1

### REMOVAL AND DISPOSAL OF CHEMICALS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: February 2, 2024  
BY: Matt Gillies  
TELEPHONE NO. 204 986-2219

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **February 9, 2024.**

#### **QUESTIONS AND ANSWERS**

Q1: Can you provide an approximate volume for each chemical?

- 1 Sulphuric Acid (93%)
- 2 Ferric Sulphate (43%)
- 3 Sodium Hydroxide (50%)
- 4 Sodium Hypochlorite (12%, 0.8%)
- 5 Sodium Bisulphite (38%)
- 6 Hydrofluorosilicic Acid (25%)
- 7 Phosphoric acid (75%)

A1: Approximate volume in liters remaining in each tank that would be required to be removed and disposed of prior to tank inspections would be as follows:

- Approximately 2500L or less would be remaining per tank for Hydrofluorosilicic Acid and Phosphoric Acid tanks;
- Approximately 5000L or less would be remaining per tank for Sulphuric Acid, Ferric Sulphate, Sodium Hydroxide and Sodium Hypochlorite tanks;
- Sodium Bisulphite tank typically wouldn't need to be pumped out and would only need to be in very rare occasions. Sodium Bisulphite tank is 3000L capacity.