

**City of Winnipeg
Water and Waste Department
North End Water Pollution Control Centre Monitoring Data
August 2019**

| Licence 2684 RRR | File # 1071.10 | Final Effluent 24 Hour Composite | | | | | | | Final Effluent Grab Sample | | | |
|---------------------|-------------------|-------------------------------------|-----------|----------|--------------|---------------------|---------------------|-------------------|-------------------------------|-------------|-------------------|------------|
| | | TSS | BOD5 | cBOD5 | Ammonia | Ortho Phosphorus | Total Phosphorus | Total Nitrogen | Temp. | pH | Fecal Coliform | E.Coli |
| | | | | | | | | | | | | |
| 1-Aug-19 | 148.7 | 12 | 12 | 4 | 4,773 | 4.44 | 3.7 | 37.6 | 20.2 | 6.74 | 100 | 120 |
| 2-Aug-19 | 147.8 | 8 | 12 | 5 | 4,671 | 4.27 | 3.7 | 37.4 | 20.4 | 6.73 | 30 | 20 |
| 3-Aug-19 | 130.6 | 8 | 11 | 5 | 4,008 | 4.12 | 3.7 | 37.1 | 20.6 | 6.74 | 20 | 20 |
| 4-Aug-19 | 127.7 | 10 | 11 | 5 | 3,781 | 3.95 | 3.7 | 36.8 | 20.6 | 6.68 | 10 | 30 |
| 5-Aug-19 | 132.1 | 13 | 13 | 5 | 3,554 | 4.17 | 3.7 | 36.3 | 20.2 | 6.69 | 10 | 40 |
| 6-Aug-19 | 138.5 | 10 | 15 | 5 | 3,768 | 4.32 | 3.7 | 36.1 | 20.3 | 6.64 | 50 | 20 |
| 7-Aug-19 | 138.5 | 16 | 17 | 7 | 4,196 | 4.40 | 3.7 | 36.2 | 20.1 | 6.71 | 10 | 20 |
| 8-Aug-19 | 146.1 | 16 | 19 | 6 | 4,500 | 4.30 | 3.8 | 36.6 | 20.0 | 6.70 | 40 | 50 |
| 9-Aug-19 | 143.4 | 20 | nr | nr | 4,432 | 4.20 | 3.9 | 37.4 | 20.3 | 6.69 | 80 | 50 |
| 10-Aug-19 | 223.5 | 68 | >70 | >39 | 5,365 | 3.78 | 4.0 | 37.5 | 19.9 | 6.60 | 40 | 60 |
| 11-Aug-19 | 144.8 | 30 | 23 | 17 | 2,230 | 1.13 | 4.0 | 36.8 | 20.4 | 6.53 | 17,300 | 24,200 |
| 12-Aug-19 | 135.8 | ns | ns | ns | ns | ns | 4.0 | 36.7 | 20.0 | 6.54 | 450 | 230 |
| 13-Aug-19 | 153.1 | 21 | 13 | 7 | 4,532 | 2.42 | 4.0 | 37.6 | 20.1 | 6.66 | 160 | 190 |
| 14-Aug-19 | 142.6 | 20 | 13 | 5 | 5,105 | 3.74 | 4.1 | 38.8 | 20.3 | 6.76 | 610 | 410 |
| 15-Aug-19 | 161.9 | 17 | 12 | 5 | 5,035 | 3.28 | 4.1 | 39.1 | 20.1 | 6.71 | 910 | 740 |
| 16-Aug-19 | 142.1 | 13 | nr | nr | 4,674 | 3.55 | 4.1 | 39.0 | 20.4 | 6.70 | 340 | 140 |
| 17-Aug-19 | 128.1 | 14 | 13 | 4 | 4,099 | 4.16 | 4.1 | 39.0 | 20.2 | 6.71 | 110 | 120 |
| 18-Aug-19 | 127.7 | 18 | 12 | 5 | 4,315 | 4.07 | 4.2 | 39.5 | 20.4 | 6.72 | 110 | 120 |
| 19-Aug-19 | 134.7 | 50 | nr | nr | 4,204 | 5.31 | 4.2 | 39.7 | 20.1 | 6.64 | 20 | 70 |
| 20-Aug-19 | 227.2 | 19 | 15 | 8 | 3,725 | 2.31 | 4.2 | 39.1 | 19.5 | 6.64 | 3,870 | 8,160 |
| 21-Aug-19 | 138.6 | 12 | 14 | 5 | 3,978 | 2.67 | 4.1 | 39.3 | 20.0 | 6.52 | 360 | 300 |
| 22-Aug-19 | 136.6 | 10 | 22 | 8 | 4,588 | 3.79 | 4.1 | 39.8 | 20.4 | 6.61 | 180 | 150 |
| 23-Aug-19 | 134.2 | 11 | 12 | 7 | 4,107 | 4.15 | 4.1 | 40.2 | 20.3 | 6.75 | 190 | 230 |
| 24-Aug-19 | 126.0 | 16 | 25 | 8 | 3,892 | 4.41 | 4.1 | 40.6 | 20.4 | 6.67 | 30 | 20 |
| 25-Aug-19 | 336.5 | 33 | 40 | 17 | 5,149 | 1.85 | 4.1 | 40.1 | 19.6 | 6.56 | 500 | 620 |
| 26-Aug-19 | 320.8 | 18 | 18 | 9 | 4,107 | 1.18 | 4.0 | 39.4 | 19.3 | 6.66 | 1,020 | 700 |
| 27-Aug-19 | 292.2 | 13 | 11 | 5 | 6,166 | 2.37 | 4.0 | 39.3 | 18.5 | 6.71 | 3,260 | 4,350 |
| 28-Aug-19 | 172.1 | 7 | 10 | 4 | 4,457 | 3.56 | 4.0 | 39.4 | 19.3 | 6.69 | 430 | 310 |
| 29-Aug-19 | 141.1 | 8 | 12 | 6 | 3,740 | 4.44 | 4.0 | 39.5 | 19.7 | 6.55 | 400 | 400 |
| 30-Aug-19 | 149.8 | 13 | 17 | 5 | 3,729 | 3.96 | 4.0 | 39.5 | 20.0 | 6.56 | 400 | 420 |
| 31-Aug-19 | 280.8 | 75 | 39 | 18 | 3,510 | 2.00 | 4.0 | 38.9 | 17.7 | 6.61 | (>24200) | (>24200) |
| Max: | 336.5 | | | | | | | | | | | |
| Min: | 126.0 | | | | | | | | | | | |
| Average: | 167.9 | 20 | 17 | 7 | 4,280 | 3.54 | | | 20.0 | 6.66 | | |
| Total Flow: | 5203.6 | | | | | | | | | | | |
| Geo.Mean: | | | | | | | | | | | 165 | 177 |

Notes:

- (1) Effluent ammonia load based upon Raw Sewage flows and Final NH3-N concentrations
- (2) nr - not recorded or no result; na - not analyzed; ns - no sample
- (3) Where value is expressed as less than (<), the value is halved and used in the calculations
- (4) * = 30 day rolling average
- (5)** Flow, highlighted in bold, in excess of 380 ML/D per clause 26 of Licence 2684RRR

- (6) Bracketed Coliform results not used in the Geometric Mean calculation
- (7) Raw wastewater flows in excess of 400 ML/D will by-pass the secondary process and flows in excess of 675 ML/D will cause raw sewage to by-pass the plant