

**City of Winnipeg
Water and Waste Department
North End Water Pollution Control Centre Monitoring Data**

May 2010

Date	Raw Sewage	Final Effluent 24 Hour Composite										Final Effluent Grab Sample			
	Daily Flow	TSS	BOD5	cBOD5	Ammonia		Ortho Phosphorus	Total Phosphorus		Total Nitrogen		Temp.	pH	Fecal Coliform	E.Coli
	ML**	(mg/L)	(mg/L)	(mg/L)	(mg/L-N)	(kg NH3-N/day)	(mg/L-P)	(mg/L-P)	(mg/L-P)*	(mg/L-N)	(mg/L-N)*	(°C)	(units)	MPN/100 mL	
1-May-10	331.9	9	14	5	10	3,419	1.06	1.3	3.5	13	25	13	6.98	490	330
2-May-10	303.5	17	17	7	11	3,339	1.36	1.8	3.5	12	24	13	7.02	(790)	(170)
3-May-10	243.1	9	17	6	13	3,258	1.62	2.4	3.5	15	24	14	6.97	330	170
4-May-10	274.1	60	39	18	11	3,097	1.53	2.6	3.5	14	24	14	6.77	49	33
5-May-10	549.9	82	37	15	6	3,332	0.61	1.9	3.5	10	24	11	7.09	(16,000,000)	(16,000,000)
6-May-10	319.7	13	17	6	10	3,197	1.01	1.6	3.4	13	23	12	7.15	170	79
7-May-10	266.4	14	13	9	13	3,516	1.45	2.0	3.4	14	23	13	7.10	170	170
8-May-10	236.7	7	13	4	14	3,408	1.77	2.3	3.3	16	23	13	7.06	17	8
9-May-10	219.8	15	21	4	15	3,231	2.14	2.7	3.3	16	22	14	7.03	170	170
10-May-10	254.6	13	28	4	15	3,768	2.05	2.7	3.3	16	22	14	6.94	(49)	(33)
11-May-10	261.4	12	22	4	14	3,633	1.90	2.4	3.3	15	22	14	7.04	460	220
12-May-10	215.3	10	21	4	17	3,596	2.28	3.0	3.2	20	21	14	7.03	790	790
13-May-10	208.1	11	29	4	17	3,579	2.44	3.2	3.2	23	21	16	7.09	11	8
14-May-10	202.1	12	22	3	18	3,638	2.62	3.2	3.2	21	21	14	6.92	13	8
15-May-10	192.1	18	nr	nr	17	3,246	2.70	3.2	3.2	18	21	15	7.04	11	11
16-May-10	187.1	8	33	3	17	3,181	2.89	3.3	3.2	23	21	15	6.99	13	8
17-May-10	191.4	10	35	4	19	3,675	3.05	3.6	3.1	21	20	16	6.93	8	8
18-May-10	192.3	12	29	5	20	3,808	2.91	3.6	3.1	24	20	16	6.88	13	8
19-May-10	190.6	11	27	4	20	3,736	2.95	3.7	3.1	27	20	15	6.88	15	9
20-May-10	190.7	7	32	4	20	3,776	3.11	3.6	3.1	26	20	17	6.84	4	4
21-May-10	186.4	12	33	5	19	3,560	2.91	3.6	3.1	26	20	17	6.72	9	9
22-May-10	165.1	13	26	5	20	3,285	3.01	3.9	3.1	28	20	16	6.99	9	4
23-May-10	201.9	6	28	4	14	2,746	2.05	2.6	3.0	19	20	16	6.99	93	15
24-May-10	186.8	40	37	15	3	587	1.91	3.1	3.0	20	20	15	6.93	4	4
25-May-10	408.5	24	27	6	7	3,047	1.07	1.7	2.9	13	19	16	6.95	(75)	(75)
26-May-10	222.7	13	15	4	15	3,430	1.82	2.3	2.9	21	19	16	6.88	93	93
27-May-10	213.9	15	22	5	19	4,043	2.45	2.9	2.8	25	19	16	6.98	4	4
28-May-10	511.2	89	43	18	7	3,783	1.03	1.9	2.7	14	18	15	6.86	(43,000)	(43,000)
29-May-10	570.1	94	32	12	3	1,539	0.50	1.2	2.6	9	18	15	7.12	(93)	(93)
30-May-10	690.8	66	25	17	3	2,321	0.55	1.2	2.6	10	18	15	7.28	(11,0000)	(11,0000)
31-May-10	697.2	58	29	17	3	2,315	0.74	1.4	2.6	13	18	14	7.48	(>110,000)	(>110,000)
Max:	697														
Min:	165														
Average:	293	25	26	7	13	3,229	1.92	2.6		18		15	7.00		
Geo.Mean:														35	24

Notes:

- (1) Effluent ammonia load based upon Raw Sewage flows and Final NH3-N concentrations
- (2) nr - not recorded or no result; na - not analyzed; ns - no sample
- (3) Where value is expressed as less than (<), the value is halved and used in the calculations.
- (4) * = 30 day rolling average

- (5)** Flow, highlighted in bold, in excess of 380 ML/D per clause 26 of Licence 2684RRR.
- (6) Bracketed Coliform results not used in the Geometric Mean calculation.
- (7) Raw wastewater flows in excess of 400 ML/D will by-pass the secondary process and flows in excess of 675 ML/D will cause raw sewage to by-pass the plant.
- (8) Total Nitrogen results are calculated from TKN and nitrate values.