



Water and Waste Department • Service des Eaux et des Déchets

September 30, 2005

Our Files: 040-17-08-27-00
040-17-08-15-00

Mr. Mike Van Den Bosch, P.Eng.
Environmental Assessment and Licensing Branch
Manitoba Conservation
Suite 160 – 123 Main Street
Winnipeg, Manitoba
R3C 1A5

Dear Mr. Van Den Bosch:

**RE: AUGUST 2005 MONITORING REPORTS FOR THE WEST END WATER
POLLUTION CONTROL CENTRE LICENCE NO. 2669 E R AND THE NORTH
END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 R**

Attached please find the August 2005 Monitoring Reports for Licence No. 2669 E R issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC) and Licence No. 2684 R issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC).

Please note the following respecting the report for Licence #2669 E R:

1. On August 12 there were no results for pH or temperature because a grab sample was not taken.

Please note the following respecting the report for Licence #2684 R:

1. On August 1, 4, 5, 6, 7, 8, 11, 12, 13, 18, 20 and 21 you will note that the raw sewage flow values on the attached monitoring report are bolded. As explained in the note on the report, flow values were adjusted using flow-monitoring data from the secondary flow meter. This was due to the flow meter on Pump MP-4 being defective resulting in inaccurate total raw flows. MP-4 had to be used during the noted days in August to replace a pump that was taken out of service for maintenance. We are expecting the defective meter to be fixed during October 2005.
2. On August 1 no temperature result was recorded from the grab sample taken.
3. On August 22 the pH was not measured on the grab sample taken.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 986-4807 or by email at kkjartanson@winnipeg.ca.

Embrace the Spirit • Vivez l'esprit

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK:kk:pr
Attachments

c: Cliff Lee, P.Eng., Assistant Director of Red River Region
B.D. MacBride, P.Eng.
W.J. Borlase, P.Eng.
M.A. Shkolny, P.Eng.

N:\Clerks\patsy's computer\OFFICE\word\kjt\VanDenBosch-ltr5.doc