



Water and Waste Department • Service des eaux et des déchets

November 30, 2005

Our Files: 040-17-08-27-00
040-17-08-15-00

Mr. Mike Van Den Bosch, P.Eng.
Environmental Assessment and Licensing Branch
Manitoba Conservation
Suite 160 – 123 Main Street
Winnipeg, Manitoba
R3C 1A5

Dear Mr. Van Den Bosch:

**RE: OCTOBER 2005 MONITORING REPORTS FOR THE WEST END WATER
POLLUTION CONTROL CENTRE LICENCE NO. 2669 E R AND THE NORTH
END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 R**

Attached please find the October 2005 Monitoring Reports for Licence No. 2669 E R issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC) and Licence No. 2684 R issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC).

Please note the following respecting the report for Licence #2669 E R:

1. On October 15 there was no result for temperature because the result was not recorded.

Please note the following respecting the report for Licence #2684 R:

1. On October 4, 8, 10, 11, 19, 20, 21, 22, 23, 24, 25 and 26 you will note that the raw sewage flow values on the attached monitoring report are bolded. This is as explained in the note with detail having been provided in the August report.
2. On October 13 there was a problem with the digestion procedure for TP. The total phosphorus result was therefore not reported.
3. On October 22, 23 and 25 there was a problem with the raw sewage flow signal from MP-4 and samples collected were not representative, therefore results for the composite samples are not provided. This is a similar problem to Item #1 above. Wastewater Services staff continue to try to correct the problem.
4. On October 26 there was a problem with the digestion procedure for TN. The total nitrogen result was therefore not reported.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 986-4807 or by email at kkjartanson@winnipeg.ca.

Embrace the Spirit • Vivez l'esprit

Mailing Address/Adresse Postale: 2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • www.winnipeg.ca

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK:kk:pr
Attachments

c: Cliff Lee, P.Eng., Assistant Director of Red River Region
B.D. MacBride, P.Eng.
W.J. Borlase, P.Eng.
M.A. Shkolny, P.Eng.

N:\Clerks\patsy's computer\OFFICE\word\kjt\VanDenBosch6-ltr.doc