



Water and Waste Department • Service des eaux et des déchets

February 22, 2006

Our Files: 040-17-08-27-00
040-17-08-15-00

Mr. Mike Van Den Bosch, P.Eng.
Environmental Assessment and Licensing Branch
Manitoba Conservation
Suite 160 – 123 Main Street
Winnipeg, Manitoba
R3C 1A5

Dear Mr. Van Den Bosch:

**RE: JANUARY 2006 MONITORING REPORTS FOR THE WEST END WATER
POLLUTION CONTROL CENTRE LICENCE NO. 2669 E R AND THE NORTH
END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 R**

Attached please find the January 2006 Monitoring Reports for Licence No. 2669 E R issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC) and Licence No. 2684 R issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC).

Please note the following respecting the report for Licence #2669 E R:

1. On January 9 and 21, there were no results for total phosphorus due to digestion errors.

Please note the following respecting the report for Licence #2684 R:

1. On January 7, there was no result for total phosphorus due to a digestion error.
2. On January 11, there was no result for ortho phosphorus due to a laboratory error.
3. On January 17, 19 and 31, there were short shut-downs (3 to 5 1/2 hours duration) at the NEWPCC to allow for inspection and repair of the plant effluent conduit. Wastewater was backed up in the interceptors for the time periods so that untreated wastewater was not discharged. The shut-downs may have had a minor impact on the composite samples taken on those days.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 986-4807 or by email at kjartanson@winnipeg.ca.

Embrace the Spirit • Vivez l'esprit

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards

KJTK:kk:pr
Attachments

c: Cliff Lee, P.Eng., Assistant Director of Red River Region
B.D. MacBride, P.Eng.
W.J. Borlase, P.Eng.
M.A. Shkolny, P.Eng.

N:\Clerks\patsy's computer\OFFICE\word\kjt\Bosch5-ltr.doc