



Water and Waste Department • Service des eaux et des déchets

---

August 29, 2014

Our Files: 040-17-08-29-00  
040-17-08-15-00  
040-17-08-35-00

Don Labossiere  
Director, Environmental Compliance and Enforcement  
Manitoba Conservation and Water Stewardship  
123 Main Street  
Winnipeg MB R3C 1A5

Dear Mr. Labossiere:

**RE: JULY 2014 MONITORING REPORTS FOR THE WEST END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2669 E RR, THE NORTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 RRR AND THE SOUTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2716 RR**

Attached please find the July 2014 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC). This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

1. We are pleased to report that the ammonia results have met the limit set in the licence. The total nitrogen and total phosphorus thirty-day rolling averages met the limits set in the licence in July.
2. The TSS results exceeded the licence limit on 7 days in July. The high TSS values were due to algae growth in the ponds which contributed to the increased TSS results.
3. The cBOD5 results met the limit set in the licence in July.
4. We are pleased to report that during the month of July the fecal coliform and E. coli results met the limits set in the licence.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS results met the limit set in the licence in July.
2. The BOD5 results met the limit set in the licence in July.
3. We are pleased to report that during the month of July the fecal coliform and E. coli results met the limits set in the licence.

Please note the following respecting the report for Licence #2716 RR:

1. The TSS results met the limit set in the licence in July.
2. The cBOD5 results met the limit set in the licence in July.
3. We are pleased to report that during the month of July the E. coli result met the limit set in the licence.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-4807 or by email at [kkjartanson@winnipeg.ca](mailto:kkjartanson@winnipeg.ca).

Please note that I will be retiring from the City effective September 6, 2014. You will be advised of my replacement in due course.

Thank you for your on-going cooperation over the last several years.

Yours sincerely,

*Original signed by:*

K.J.T. Kjartanson, P.Eng.  
Manager of Environmental Standards

KJTK/rg  
Attachments

c: D. P. Sacher, P.Eng. (e-mail)  
C. Carroll, P.Eng. (e-mail)

N:\Compliance Reporting\WPCC Monthly\2014 Submitted Letters\Submittal Letter WPCC Monitoring July 2014.doc