



Water and Waste Department • Service des eaux et des déchets

August 28, 2015

Our Files: 040-17-08-29-00
040-17-08-15-00
040-17-08-35-00

Don Labossiere
Director, Environmental Compliance and Enforcement
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg MB R3H 0W4

Dear Mr. Labossiere:

RE: JULY 2015 MONITORING REPORTS FOR THE WEST END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2669 E RR, THE NORTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2684 RRR AND THE SOUTH END WATER POLLUTION CONTROL CENTRE LICENCE NO. 2716 RR

The July 2015 Monitoring Reports for Licence No. 2669 E RR issued for the City of Winnipeg West End Water Pollution Control Centre (WEWPCC), Licence No. 2684 RRR issued for the City of Winnipeg North End Water Pollution Control Centre (NEWPCC) and Licence No. 2716 RR issued for the City of Winnipeg South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

1. There were no results for the 24 hour composite sample on July 20, 21, and 22 due to a sampler malfunction.
2. The TSS results met the licence limit in July.
3. The cBOD5 results met the licence limit in July.
4. The ammonia results and the total nitrogen thirty-day rolling average met the limits set in the licence in July. The total phosphorus thirty-day rolling average exceeded the licence limit on 19 days in July. The total phosphorus results met the licence limit coming out of the treatment plant, but the levels increased through the polishing cell.
5. The monthly geometric mean for fecal coliform and E. coli met the licence limits in July.

Please note the following respecting the report for Licence #2684 RRR:

1. The TSS results exceeded the licence limit on 3 days in July due to intermittent high flows and bypass events.
2. The BOD5 results exceeded the licence limit on 3 days in July due to intermittent high flows and bypass events.
3. The monthly geometric mean for fecal coliform and E. coli met the licence limits in July.

Please note that all results reported for Licence #2716 RR met the licence requirements in July.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Thank you for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

RG
Attachments

c: D. P. Sacher, P.Eng. (e-mail)
C. Carroll, P.Eng. (e-mail)

N:\Compliance Reporting\WPCC Monthly\2015 Submittal Letters WPCC\2015-07 Submittal Letter WPCC Monitoring.doc