



Water and Waste Department • Service des eaux et des déchets

June 22, 2015

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

| <u>LOCATION</u> | <u>SAMPLE NUMBER</u> | <u>DATE</u> | <u>RESULT(mg/L F)</u> |
|---------------------------------------------------|-----------------------------|--------------------|------------------------------|
| Distribution System (Composite – 39 Locations) | 431324 | May 4, 2015 | 0.68 |
| | 432048 | May 11, 2015 | 0.65 |
| | 432881 | May 19, 2015 | 0.65 |
| | 433685 | May 25, 2015 | 0.66 |

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2015\Fluoride\2015-05 Fluoride.doc