



Water and Waste Department • Service des eaux et des déchets

November 13, 2015

Our File: 040-18-18-14-00

Dr. Khalida Hai-Santiago c/o Helen Browne
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

Dear Dr. Hai-Santiago:

RE: CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

<u>LOCATION</u>	<u>SAMPLE NUMBER</u>	<u>DATE</u>	<u>RESULT(mg/L F)</u>
Distribution System (Composite – 39 Locations)	448888	October 5, 2015	0.69
	449559	October 13, 2015	0.65
	450246	October 19, 2015	0.53
	451115	October 26, 2015	0.64

The low distribution system fluoride result on October 19 was due to an operational error with the fluoride analyzer. If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours truly,

Original signed by:

Renée Grosselle
Manager of Environmental Standards

NC/HD

cc: Tim Shanks, P.Eng. Manager of Water Services (e-mail)

N:\Compliance Reporting\Submittal Letters\2015\Fluoride\2015-10 Fluoride.doc