



Water and Waste Department • Service des eaux et des déchets

March 18, 2015

Our File: 040-18-18-55-00

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba
R3H 0W4

Dear Ms. Betsill:

**RE: TOTAL TRIHALOMETHANE SUMMARY REPORT
FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM FOR QUARTER 1 - 2015**

Please find attached the Total Trihalomethane Summary Report for the first quarter of 2015 for the Winnipeg water supply system for your review and records.

Please let me know of any concerns or questions respecting this submission. I may be reached at the below address, by telephone at 204-986-8359 or by e-mail at rgrosselle@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

R. Grosselle
Manager of Environmental Standards

RG/nc
Attachments

c: Dr. L. Richards, Winnipeg Regional Health Authority
Dr. H. Chang, Winnipeg Regional Health Authority
Dr. S. Roberecki, Manitoba Health
D.P. Sacher, P.Eng.(e-mail)
G. Patton, P.Eng. (e-mail)
T. Shanks, P.Eng. (e-mail)
C. Diduck (e-mail)

N:\Compliance Reporting\Submittal Letters\2015\THM\2015-Q1 THM Submittal Letter.doc

Embrace the spirit • Vivez l'esprit

Environmental Standards Division • Division des normes environnementales
2230 Main Street • 2230, Rue Main • Winnipeg • Manitoba R2V 4T8
tel/tél. (204) 986-4684 • fax/télec. (204) 339-2147 • www.winnipeg.ca

**CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION**

Total Trihalomethane Summary Report

Reporting Period: Quarter 1 2015

SAMPLE DATE	DISTRIBUTION SYSTEM THM RESULTS (ug/L)					
Monday, May 05, 2014	13	12	12	13	13	14
Monday, August 11, 2014	40	40	40	38	42	40
Monday, November 10, 2014	25	21	26	27	27	23
Monday, February 09, 2015	14	11	14	14	13	12
RUNNING AVERAGE THM	23	21	23	23	24	22

COMMENTS:

NS - NO SAMPLE
NR - NO RESULT

Methodology

Trihalomethanes analyzed by GC-ECD, Standard Methods for the Examination of Water and Waste Water, 21st Edition, Method 6232

Report Compiled by: H.Demchenko

Approved in LIMS by: C.Diduck

File: WQR4

Date Approved: February 24, 2015

N:\Environmental Standards\Analytical Services\WQ Data\Routine Water Quality\2015\Quarterly THM\Quarterly THM 2015.xls]THM Q1